



MUNICIPAL CORPORATION CHANDIGARH

Public Health Laboratory at Water Works Sector - 39

TEST - REPORT

Not for legal use

Ref. No. & Date : - No.GHS/50/2024-25/570 dated: 25.03.2025
Issued to : - The Headmistress
: - Govt High School
: - Sector - 50,B,Chandigarh
Quantity of sample : - Approximate 1200 ml.
Date of Collection : - 29-03-2025
Client reference : - Sample Collected by Laboratory Staff
Packing of sample : - Sample filled in P.P. and Glass Bottle
Source of sample : - from School tap of Govt High School,
Sector - 50,B Chandigarh


S.No.	Examination	Quality Standard	Unit	Result
1	pH	6.5 - 8.5	-----	7.75
2	Odour	Agreeable	-----	Agreeable
3	Taste	Agreeable	-----	Agreeable
4	Turbidity	< 1.0	N.T.U.	0.7
5	Residual Chlorine	0.2 - 0.4	mg/l	0.2
6	Total Alkalinity (as CaCO ₃)	< 200	mg/l	82
7	Total Hardness (as CaCO ₃)	< 200	mg/l	70
8	Chloride (as Cl)	< 250	mg/l	04
9	Free & Saline Ammonia	NIL	mg/l	NIL
10	Total Dissolved Solids	< 500	mg/l	128
11	M.P.N. of Coliform Bacilli Per 100ml of water	Zero	M.P.N.	0 (Excellent)


Payment received videreceipt No.03/2024-25/240631, dated 26.03.2025, Amount Rs.3300/-

Note: Water is fit for drinking.

Lab No.- MCPHL/25/ ...1074...

Dated:- 02.04.2025



Chemist
M.C.P.H. Laboratory
Chandigarh



Sub Divisional Engineer,
M.C.P.H. Sub Division No.1
Chandigarh

Dated :-02.04.2025

Endst No. MCPH/25/.....

Copy forwarded to the Medical Officer of Health Municipal Corporation, Sector-17, Chandigarh
For Information Please.


Chemist
M.C.P.H. Laboratory
Chandigarh


Sub Divisional Engineer,
M.C.P.H. Sub Division No.1
Chandigarh